




OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER: KHAMMAM
Rc. No: 07/School/IDSP/2022

Date: 08-03-2022.

SANITARY CERTIFICATE

This is to certify that the management of Harvest Public School, #5-7-200/11, Pakabanda Bazar, Khammam (Urban Mandal), Khammam District has provided pure drinking water for students. The classes are sufficient for the maximum number of pupils and they are properly ventilated and lighted. In all aspects the sanitation is satisfactory as per the inspection report submitted by the District Surveillance Officer, Integrated Disease Surveillance Programme (IDSP), Khammam and may issue No Objection Certificate for Early start of Admissions for the Academic Year 2022-23.

This certificate is valid upto one year from date of issue.



District Medical and Health Officer
Khammam.


Dist. Medical & Health Officer
Khammam

Date: 08-03-2022
Station: Khammam.


Secretary & Correspondent
Harvest Public School
Khammam


PRINCIPAL
Harvest Public School
Khammam



Natural Resources Development Co-Operative Society Ltd.,

Dr. Gorkey Complex, Wyra Road, KHAMMAM - 507 001.

Reg.No.T.A.602

e-mail: nrdcskmm@gmail.com

REF: CAC/KMM/21-22/

Dt : 12.03.2022

Name and Address of
the Customer

: The Secretary & Correspondent,
Harvest Public School,
D.No.5-7-200/11, Pakabanda Bazar,
Mamatha Hospital Road,
KHAMMAM..

Details of the samples

: Water sample received from Borewell on
10.03.2022.

Results:

S.No	CONSTITUENTS	Values	Max. Per. Limits as per IS:10500.
A. PHYSICAL :			
1.	Colour (Hazan Units)	<2	15
2.	PH	7.46	6.50 – 8.50
3.	Electrical Conductivity (Microsiemens/Cm)	1400	--
4.	Turbidity (NTU)	<2	5
B.CHEMICAL :			
5.	Dissolved Solids	850	2000
6.	Total Hardness as CaCO ₃	400	600
7.	Alkalinity to phenolphthalein as CaCO ₃	Nil	--
8.	Alkalinity to methyl orange as CaCO ₃	290	600
9.	Non-Carbonate as CaCO ₃	110	--
10.	Calcium as Ca	94.40	200
11.	Magnesium as Mg	39.852	100
12.	Sodium as Na	136	--
13.	Chloride as Cl	160	1000
14.	Sulphate as SO ₄	170	400
15.	Silica as SiO ₂	8	--
16.	Iron as Fe	0.101	0.30
17.	Nitrate as NO ₃	8.85	45
18.	Fluoride as F	1.10	1.50
19.	Potassium as K	3	--
Values are expressed in mg/l, except PH.			
C. BACTERIOLOGICAL :			
20.	MPN of Coliform bacteria per 100ml	Nil	Nil
21.	E – Colie per 100 ml	Absent	Absent

Note : All the above constituents are within the permissible limits and the above water is useful for human consumption.

P. David...
Secretary & Correspondent
Harvest Public School
Khammam

R. Prasanna
PRINCIPAL
Harvest Public School
Khammam

Consulting Geologists, Geo-Physicists, Chemists, Geo - Technical Investigators (K.B.SRINIVAS)
Head Office : Himayath Nagar, HYDERABAD - 29. CHEMIST.